



C E R T I F I C A T E

Certificate No. 10-PPV-0003808/01-W01-TIC

WE HEREBY CERTIFY THAT THE PHOTOVOLTAIC MODULES WITH THE MODEL
GB72P6-240, GB72P6-270

(Tested Type)

Tested Type	Cell Number	Cell Size	Cell Technology	Power [W]
GB72P6-240	72	6"	Polysilicon	240
GB72P6-270	72	6"	Polysilicon	270

Types extended for similarity* with Polysilicon cell technology without need of re-testing
(according to IECCE "Retesting guideline"):

Type	Cell Number	Cell Size	Power [W]
GB72P6-XXX*	72	6"	from 240 to 300
GB60P6-XXX*	60	6"	from 200 to 250
GB54P6-XXX*	54	6"	from 185 to 225

MANUFACTURER & LICENSE HOLDER

GreenBrilliance Energy Pvt. Ltd.

A1/3-4 BIDC Industrial Estate (Gorwa), Vadodara, India 390 016

IS IN COMPLIANCE WITH THE REQUIREMENTS OF

IEC 61215 : 2005

Crystalline silicon terrestrial photovoltaic (PV) modules – Design qualification and type approval
&

EN 61730-1 / EN 61730-2 : 2007**

Photovoltaic (PV) module safety qualification

To be used in plants at a total voltage up to : 1000 Vdc

AS RESULT OF THE TEST IN OUR APPOINTED LABORATORY

EA ACCREDITED LABORATORY N. 0192

REPORT No. TIC-PVM01CdO08C360001, TIC-PVS01CdO08C360001

TIC-3185405LAX-001a

&

The factory inspection on the production site:

Green Brilliance Energy Pvt. Ltd. (Vadodara - India)

on the date 25th July 2013 With REPORT No. RFF-0713-PPV-TIC-0003808

First issuing 11.02.2010

Expiring date 04.09.2018

(Providing that the testing basis continues unchanged)

Notes: (*) The manufacturer declares that these products are constructed using the same materials, components and processes as the tested type GB72P6-240. Technical data, materials and components description are into the indicated test reports. Any changes of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval. Suffix XXX indicates rated power. (**)The certification is performed on tested model as complete certification and the fire test (IEC 61730-2 / MST 23) was not performed. This certificate is for type approval and based on voluntarily product test. The Manufacturer Inspection is conducted by TÜV INTERCERT on the base of the internal procedures.



DAT-ZE-030/09-00



Am Bonner Bogen 2, D-53227 Bonn,



05.09.2013 Dipl.- Ing. F. Sergizzarea

TÜV INTERCERT Certification Body

CERTIFICATE ■ CERTIFICATO ■ ZERTIFIKAT ■ SERTIFIKA ■ CERTIFICADO ■ گواهینامه ■ ΠΙΣΤΟΠΟΙΗΤΗ

CERTIFICATE ■ CERTIFICATO ■ ZERTIFIKAT ■ SERTIFIKA ■ CERTIFICADO ■ گواهینامه ■ ΠΙΣΤΟΠΟΙΗΤΗ